

AMEER DIAGNOSTIC LABORATORY

DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 3-011-13-LW-2 & 03-0794-15-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

PLDT No.: (044) 662 6448 Globelines: 305 0430 ; Cell No. 0925 525 5504 / 0925 525 5505 / 0923 737 8982 / 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

Date of Issue:

December 8, 2015

I. Sample Information

Client / Business Name : **GAPAN WATER DISTRICT**
Address : **GAPAN, NUEVA ECIJA**
Sample Taken By : **ROY ABELLA**
Date of Sampling : **December 4, 2015**
Date Received : **December 4, 2015**
Source of Sample : **DEEPWELL**

II. Test Results

Type of Test : **Heterotrophic Plate Count**

	CONCESSIONAIRE	Time of Sampling	Result CFU/ml	Standard CFU/ml	REMARKS
1	EDWIN OANES - PAMBUAN	11:34 AM	390	<500	PASSED
2	ROLAND LISING - MANGINO	11:44 AM	32	<500	PASSED
3	LUCILA ESTRELLA - SAN LORENZO	11:54 AM	40	<500	PASSED
4	FREEDOM PARK PUMPING STATION	12:01 PM	390	<500	PASSED
5	BRGY. HALL - BAYANIHAN	12:11 PM	45	<500	PASSED
6	MA. TESSIE RIVERA STO. CRISTO NORTE	12:20 PM	455	<500	PASSED
7	ANA MAE PEREZ - STO. CRISTO SUR	12:24 PM	195	<500	PASSED
8	ROMEO TANTOCO - MALIMBA	12:34 PM	<1	<500	PASSED
9	BALUARTE PUMPING STATION	12:44 PM	<1	<500	PASSED
10	SAN NICOLAS PUMPING STATION	1:05 PM	<1	<500	PASSED

REFERENCES Philippine National Standards for Drinking Water of 2007

NOTE: Test result is based on sample as received and it is valid for one (1) month from the date issued.

RESULT VALID ONLY WITH DRY SEAL


LYNELL J. CAGUNTAS, RMT

Analyst

Susana P. Quiaoit, MD, FPSP

Head of the Laboratory

OTRL#: 5495-15 TO 5504-15



AMEER DIAGNOSTIC LABORATORY

DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 3-011-13-LW-2 & 03-0794-15-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

PLDT No.: (044) 662 6448 Globelines: 305 0430 ; Cell No. 0925 525 5504 / 0925 525 5505 / 0923 737 8982 / 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

Date of Issue:

December 8, 2015

I. Sample Information

Client / Business Name : **GAPAN WATER DISTRICT**
Address : **GAPAN, NUEVA ECIJA**
Sample Taken By : **ROY ABELLA**
Date of Sampling : **December 4, 2015**
Date Received : **December 4, 2015**
Source of Sample : **DEEPWELL**

II. Test Results

Type of Test : **Heterotrophic Plate Count**

	CONCESSIONAIRE	Time of Sampling	Result CFU/ml	Standard CFU/ml	REMARKS
1	EDWIN OANES - PAMBUAN	11:34 AM	390	<500	PASSED
2	ROLAND LISING - MANGINO	11:44 AM	32	<500	PASSED
3	LUCILA ESTRELLA - SAN LORENZO	11:54 AM	40	<500	PASSED
4	FREEDOM PARK PUMPING STATION	12:01 PM	390	<500	PASSED
5	BRGY. HALL - BAYANIHAN	12:11 PM	45	<500	PASSED
6	MA. TESSIE RIVERA STO. CRISTO NORTE	12:20 PM	455	<500	PASSED
7	ANA MAE PEREZ - STO. CRISTO SUR	12:24 PM	195	<500	PASSED
8	ROMEO TANTOCO - MALIMBA	12:34 PM	<1	<500	PASSED
9	BALUARTE PUMPING STATION	12:44 PM	<1	<500	PASSED
10	SAN NICOLAS PUMPING STATION	1:05 PM	<1	<500	PASSED

REFERENCES Philippine National Standards for Drinking Water of 2007

NOTE: Test result is based on sample as received and it is valid for one (1) month from the date issued.

RESULT VALID ONLY WITH DRY SEAL

LYNELL J. CAGUNTAS, RMT
Analyst

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory